

# Schedule 40 Specifications

## Schedule 40 Pressure Fittings

- Schedule 40 Pressure fittings are certified to meet or exceed all performance specifications of ASTM D-2466.
- Schedule 40 Pressure fittings are manufactured using a virgin PVC compound with a cell classification of 12454, Type 1, Grade 1 as defined in ASTM D-1784.
- Schedule 40 Pressure fittings conform to the geometrics and patterns as defined in ASTM D-3311 and conform to ASTM F-1498, the standard for tapered pipe thread for thermoplastic fittings.



Complete Line Molded: 3/8" to 8"



## Schedule 40 Pressure Information

DO NOT USE FITTINGS FOR COMPRESSED AIR OR GASES.

DO NOT TEST PVC PIPING SYSTEMS WITH COMPRESSED AIR OR GASES.

DO NOT USE FITTINGS WITH LIQUIDS NOT RECOMMENDED BY TIGRE.

MODIFICATION OF FITTINGS VOIDS THE WARRANTY.

SPECS SUBJECT TO CHANGE WITHOUT NOTICE